

GM200-2B/GM400-2B Operating Manual



LONGER

Baoding Longer Precision Pump Co., Ltd.

Add: 3rd/4th Floor, Building 6B, University Science Park
Baoding National, High - Tech Industrial Development Zone
Baoding, Hebei, China 071051
Tel: 86 - 312 - 3110087 3138553
Fax: 86 - 312 - 3168553
E - mail: longer@longerpump.com
[Http://www.longerpump.com](http://www.longerpump.com)

Mini Peristaltic Pump

2025.5

Baoding Longer Precision Pump Co.,Ltd.

A **Halma** company

Contents

Contents	1
1. General Information	2
1.1 Statements	2
1.2 Precautions	2
1.3 Contacts	3
2. Product Introduction	3
2.1 Main Features	3
2.2 Unpacking	3
2.3 System Structure and Dimensions	3
2.3.1 Outline Dimensions	3
2.3.2 Pump Interfaces	4
2.4 Technical Specifications	5
2.5 Applicable Tubing and Flow Rate	6
3. Operating Instructions	6
3.1 Keypad and Display	6
3.1.1 Keypad Function	7
3.1.2 LCD Display	8
3.2 Operating Instructions	9
3.2.1 Power Up	9
3.2.2 Set the Work Mode	9
3.2.3 Display Pump Speed or Time	10
3.2.4 Set the Timer Duration	10
3.2.5 Start and Stop	11
3.2.6 Change the Direction	11
3.2.7 Prime the Pump	12
3.2.8 Increase and Decrease Pump Speed	13
3.2.9 Keypad Lock	13
3.2.10 Footswitch Control Start and Stop	13
Appendix A Factory Default Settings	13

1. General Information

1.1 Statements

- Longer Pump adheres to a strategy of continuous product improvement. The upgrades, modifications or change to the pumps appearance, specification or software may occur without prior notice.
- Depending on the pump model and software version you are using, the screenshots or function descriptions in this manual may be different, please refer to the functions of the current software version.
- The pumps shown in the manual are for illustration purposes only and may differ from the actual products. Please refer to the actual items.

1.2 Precautions

- The housing of the drive is provided with grounding terminal. In order to guarantee the operator's safety and improve the electromagnetic compatibility of the equipment, please ground the product reliably.
- Please do not disassemble, refit or maintain the product without permission, so as to avoid any damage or reduction to its performance.
- All ports on the rear housing of the drive must be protected against vapor and water ingress. Ensure all ports are either connected with cables or sealed with protective covers.
- If tubing leaks or bursts, fluid may spray from the tubing and pump head. Take reasonable practicable measures to ensure the operators' safety.
- Make sure fluid in the tubing has been drained out, that there is no pressure in the pipeline and disconnect pump from mains power, while removing or replacing the tubing.
- Do not touch the rotor while pump is running.
- Release the compression block when pump stops running for a long time to avoid tubing deformation caused by occlusion.
- Keep the rotor clean and dry to avoid tubing excessive wear and premature failure of pump head or drive.
- Please do not add the lubricating oil to the rotor by yourself, any improper operation could corrode the pump head housing or dislocate the tubing
- Please connect the power cord or footswitch in correct way, and do not damage the plug.
- If the pump head can't resist organic solvent and corrosive liquid, please clean the liquid left on the surface of the pump head in time.

1.3 Contacts

- Baoding Longer Precision Pump Co., Ltd.
- Address: Floor 3-4, Block B, Building 6, University Science Park, No. 5699 North Second Ring Road, National High-tech Industrial Development Zone, Baoding City, Hebei Province, China
- Telephone: +86-312-3110087
- Website: www.longerpump.com

2. Product Introduction

2.1 Main Features


- Compact size and structure, space saving footprint with stackable design.
- Features physical button operation and a LCD display for intuitive and convenient use.
- Provides continuous and timer modes for different applications.
- High speed control accuracy up to $\pm 0.1\%$.
- Can be controlled by keypad or footswitch.
- Excellent EMC performance certified by TUV and compliant with both lab standard EN IEC 61326 and industrial standard EN IEC 61000.
- Compatible with various peristaltic pump heads (YZ1515x, YZ2515x, DG-1, DG-2) with a wide flow range.

2.2 Unpacking


- (1) Remove the pump and the accessories from the shipping carton.
- (2) Check the packing list to confirm all accessories are included.
- (3) In case of any question, please contact Longer or the local distributor.

2.3 System Structure and Dimensions


2.3.1 Outline Dimensions



GM200-2B/GM400-2B with YZ1515x(YZ2515x) Pump Head




GM200-2B/GM400-2B with DG-1 Pump Head



GM200-2B/GM400-2B with DG-2 Pump Head

2.3.2 Pump Interfaces



To enhance the EMC performance of the pump, it is recommended to connect the grounding knob to the system's protective earth (PE).

2.4 Technical Specifications


	GM200-2B	GM400-2B
Pump head material	0-200rpm	0-400rpm
Speed resolution	0.01 rpm (speed<10rpm) 0.1rpm (10rpm≤speed<100rpm) 1rpm (100rpm≤speed≤max. speed)	
Display	LCD screen for pump speed, running direction, time, start/stop status and work mode	
Running direction	Clockwise or counter-clockwise, can be toggled during running	
Work mode	Continuous or timer mode	
Control mode	Keypad or footswitch control	
Keypad control	Set the parameters and control the pump via keypad: start/stop, running direction, prime function, speed adjustment, work mode, timer	
Footswitch control	Control the start/stop via a footswitch	
Timer function	In timer mode, the pump runs and stops based on the set timer duration. Timer range: 0.1s to 999h.	
Runtime counter	In continuous mode, the pump automatically records the runtime and can accumulate the multiple operation periods (reset upon power-up). Timing range: 0.1s-999h	
Keypad lock	To prevent misoperation	
Pump status when powered up	Stop	
Parameter retention	Run and system parameters are saved after power loss	
Prime	Fast filling or emptying at full speed	
Certificates	CE,UKCA EMC standard: EN IEC 61326-1:2021, EN IEC 61000-6-1:2019, EN IEC 61000-6-2:2019, EN IEC 61000-6-3:2021, EN IEC 61000-6-4:2019	
Dimensions (L*W*H)	175mmx115mmx135mm (pump drive only)	
Power supply for adapter	AC100-240V, 50Hz-60Hz	
Power supply for pump	DC24V/15W	DC24V/30W
Working condition	Environment temperature:0°C-40°C, relative humidity:<80%	
IP rating	IP31	
Weight	1.7kg (pump drive only)	

2.5 Applicable Tubing and Flow Rate

Pump Head	Tubing		Max Flow Rate Reference (mL/min)	
	Silicone Tubing	PharMed® Tubing	GM200-2B	GM400-2B
YZ1515x (3 rollers)	13#, 14#, 19#, 16#, 25#, 17#, 18#	Not Recommended	760	1520
YZ2515x	15# 24#	Not Recommended	540	1120
DG-1 (6 rollers) DG-2 (6 rollers)	ID≤3.17mm W.T.:0.8-1mm	ID≤3.17mm W.T.:0.8-1mm	48(@100rpm, single channel)	Not Recommended
DG-1 (10 rollers) DG-2 (10 rollers)	ID≤3.17mm W.T.:0.8-1mm	ID≤3.17mm W.T.:0.8-1mm	32(@100rpm, single channel)	Not Recommended

3. Operating Instructions

3.1 Keypad and Display




3.1.1 Keypad Function

 Start/Stop Key	Press the key to start or stop the pump. When the pump is in the prime status via the Max Key, it also can be stopped by pressing this key. When the pump is running and the keypad is locked, long pressing this key can unlock the keypad and stop the pump.
 Direction Key	Press the key to toggle the pump running direction, clockwise or counter clockwise. The direction key is disabled when the pump is in the prime status via Max Key.
 Increase Key	Increase the pump speed or timer duration. Press and hold the key will increase the value quickly.
 Decrease Key	Decrease the pump speed or timer duration. Press and hold the key will decrease the value quickly.
 Clear Run Time Keys	Press the Increase and Decrease keys at the same time to reset the accumulated run time. This operation is valid whether pump is running or stopped.
 Max Key	Press the Max Key to prime the pump at full speed 100rpm, whether the pump is running or stopped. Press the key again to return to the previous status.
 Lock Key	1.Lock the keypad: Short press the Lock Key to lock the keypad. Only Stop Key and Lock Key will be functional. Other keys will be disabled. 2. Unlock the keypad: a. When the pump is running or stopped and the keypad is locked, long press the Lock Key (> 1 second) to unlock the keypad. All keys will then be functional. b. When the pump is running and the keypad is locked, long press the Start/Stop Key (> 1 second) to stop the pump and unlock the keypad.
 Unit Key	Pump in the continuous work mode: Pump running: short press the Unit Key to toggle the display between pump speed and accumulated run time. Pump stopped: short press the Unit Key to toggle the display between pump speed and accumulated run time. When displays the pump speed, long press the Unit Key to cycle through the speed units (0.01rpm, 0.1rpm and 1rpm). Pump in the timer work mode: Pump running: short press the Unit Key to toggle the display between pump speed and remaining run time. Pump stopped: short press the Unit Key to toggle the display between pump speed and timer duration. When LCD displays the pump speed, long press the Unit Key to cycle through the speed units (0.01rpm, 0.1rpm and 1rpm). When LCD displays the timer duration, long press the Unit Key to cycle through the time units (sec, min and hour).

 Mode Key	When the pump stopped, press the Mode Key to toggle the work mode between continuous mode and timer mode.
---	---

3. 1. 2 LCD Display



Icon	Name	Description	Remark
	Run	This icon will be displayed when the pump is running	Only one icon can be displayed at a time.
	Stop	This icon will be displayed when the pump is stopped	
	Counter-clockwise	This icon will be displayed when the pump is running counter-clockwise.	Only one icon can be displayed at a time.
	Clockwise	This icon will be displayed when the pump is running clockwise.	
	Keypad Lock	The lock icon appears when the keypad is locked and disappears when the keypad is unlocked.	
	Timer	The timer icon indicates that the pump is running in timer mode. When the icon is not displayed, the pump is running in continuous mode.	

	Speed or Time	1. Displays the current pump speed with unit of "rpm" Displays "---" when pump is in the prime status. 2. Displays time with unit of "sec, min or hr": a. Pump stopped in the timer mode: displays the set timer duration. b. Pump running in the timer mode: displays the remaining time (countdown). c. Continuous mode: displays the accumulated run time.	1. In timer mode, the pump can not be paused. When restarted, the countdown time will begin from the full set duration. 2. In continuous mode, the accumulated run time can be reset by the Clear Run Time Key, powering up, or switching back to continuous mode from timer mode.
	Time Unit	second	Only one icon can be displayed at a time.
	Time Unit	minute	
	Time Unit	hour	
	Speed Unit	rpm	

3.2 Operating Instructions

3.2.1 Power Up

GM200-2B operates on DC24V/8W, GM400-2B operates on DC24V/30W. The pump can be powered by connecting to a single-phase mains supply using the AC100-240V to DC24V adapter provided by Longer Pump.

Upon power-up, the pump remains in a stopped status. The work mode and parameters will be retained from the previous power-off status.


3.2.2 Set the Work Mode

The pump can run in continuous mode or timer mode. When the pump is stopped, press the Mode Key to toggle between the two modes. The timer icon will be displayed when timer mode is active.

In continuous mode, both starting and stopping the pump must be performed by pressing the Start/Stop Key or a footswitch.

In timer mode, press the Start/Stop Key or a footswitch to start the pump. The pump will stop automatically when the set timer duration expires, or it can be manually stopped by pressing the Start/Stop Key or a footswitch.

✧ Note: the mode can not be changed when the pump is running.



3. 2. 3 Display Pump Speed or Time

Whether pump is running or stopped, press the Unit Key to toggle the display between pump speed and time.

a. Continuous mode: the displayed time represents the total run time accumulated over multiple start-stop cycles.

b. Reset the accumulated run time:

When LCD displays the run time, press the Increase and Decrease Keys at the same time to reset the accumulated run time. If the pump is running at this time, it will automatically start counting from zero.

✧ Note: the accumulated time will be reset automatically when pump powered up, or switching back to continuous mode from timer mode.

c. Timer mode: the displayed time represents the set timer duration (when the pump is stopped) or remaining countdown time (when the pump is running)

✧ Note: In timer mode, the pump can not be paused. When restarted, the countdown will begin from the full set duration.

3. 2. 4 Set the Timer Duration

a. Set the time unit:

In timer mode, when the pump is stopped, short press the Unit Key to display the set timer duration (in seconds, minutes or hours). Then, long press the Unit Key to cycle through the time units: sec (seconds), min (minutes), and hr (hours).

b. Set the timer duration with the Increase or Decrease Keys:

In timer mode, when the pump is stopped, short press the Unit Key  to display the set timer duration (in seconds, minutes or hours). Use the Increase Key  or Decrease Key  to adjust the timer value. Long press the Increase or Decrease Key to adjust the value quickly.
Timer range: 0.1s to 999hrs.

3. 2. 5 Start and Stop

When the pump is stopped (display speed or time), short press the Start/Stop Key , the pump will run at the set speed and direction. The running status indicated on the screen will be .

When the pump is running (display speed or time), short press the Start/Stop Key , the pump will stop. The running status indicated on the screen will be .

✧ Note: When the keypad is locked and the pump is running, long press the Start/Stop Key for more than one second, the pump will be stopped and the keypad will be unlocked.



Running Status




Stop Status


3. 2. 6 Change the Direction

When the pump is stopped or running (displays speed or time), press the Direction Key , the pump will toggle the running direction between clockwise and counter-clockwise.

✧ Note: the direction can not be changed when the pump is in prime status (displays "---").



Clockwise



Counter-clockwise

3.2.7 Prime the Pump

When the pump is stopped or running (displays speed or time), press the Max Key  to prime the pump at full speed 100rpm and in the direction indicated. Press the key again to return to the previous status. When pump is in the prime status, the pump can be stopped by pressing Start/Stop Key , but the Direction Key  is disabled.

In continuous mode, the accumulated running time continues during prime status.

In timer mode, the countdown of the remaining time continues during prime status.



Display the Speed in the Prime Status (Continuous mode)



Display the Accumulated Run Time in the Prime status (Continuous mode)



Display the Speed in the Prime Status (Timer mode)



Display the Remaining Time in the Prime status (Timer mode)

3.2.8 Increase and Decrease Pump Speed

a. Using Increase and Decrease Keys:

When the pump is stopped or running, press the Unit Key  to display current speed in rpm. Then press the Increase or Decrease Keys   to adjust the pump speed. Press and hold the keys will quickly adjust the speed until the maximum of 200rpm/ 400rpm or minimum of 0.01rpm.

b. Change the speed unit:

When the pump is stopped, press the Unit Key  to display current speed in rpm. Then long press the Unit Key  to cycle through the speed units: 0.01rpm, 0.1rpm and 1rpm.

3.2.9 Keypad Lock

When the pump is stopped or running (displays speed or time), short press the Lock Key  to lock the keypad, then the lock icon  will appear. Then long press the Lock Key  to unlock the keypad, and the lock icon will disappear.

✧ Note: when the pump is running and the keypad is locked, long press the Start/Stop Key , the pump will stop and the keypad will be unlocked.

3.2.10 Footswitch Control Start and Stop

The pump can be controlled by a footswitch, functioning the same as the Start/Stop Key. Each press of the footswitch toggles the pump between running and stopped statuses.
The footswitch and the Start/Stop Key remain functional simultaneously.

Appendix A Factory Default Settings

Reset the pump to the factory default settings: During power-up, long press the Mode Key  until “---” appears on the display. Then, short press the Increase Key  to display “FFF”. Finally, short press the Max Key  to reset the pump to the factory default settings.

Product Model	GM200-2B	GM400-2B
Work Mode	Continuous mode	Continuous mode
Pump speed	200rpm	400rpm
Run direction	Clockwise	Clockwise
Timer duration	60s	60s
Pump status when powered up	Stop	Stop